



## FIRE UNDERWRITERS SURVEY

A SERVICE TO INSURERS AND MUNICIPALITIES

c/o CGI Information Systems and Management Consultants Inc., 90 Allstate Parkway, Markham, Ontario L3R 6H3  
Telephone: (905) 474-0003 • Toll-free: 1-800-268-8080 • Fax: (905) 474-5604

January 25, 2007

Fire Chief Dave Thompson  
Township of Seguin  
R. R. # 2, 5 Humphrey Drive  
Parry Sound, Ontario  
P2A 2W8

**Subject: Superior Tanker Shuttle Accreditation**

Dear Chief Thompson:

The Fire Underwriters' Survey is pleased to give your municipality Superior Tanker Shuttle Accreditation. The test procedure was carried out on September 24, 2003 with the undersigned present. The flow rate during the 2-hour test period averaged 2,045 litres per minute or 450 imperial gallons per minute.

Your team worked in a well co-ordinated and organized manner with proper supervision.

Regards,

Peter J. Rose, C.E.T., F.P.T.  
Fire Protection Specialist

Note: This is a replacement letter for the one issued September 26, 2003 to Fire Chief Pete Barbour.