

## **Fire Department Water Tanker Shuttle Accreditation**

**Presented To: Seguin Township**

### **ACCREDITED FIRE STATIONS**

**F.S #10 58 Rankin Road Foley (7)**

**F.S #20 4 Victoria St. Rosseau (7)**

**F.S #30 1040 Hwy. 518 Christie (8)**

**F.S #40 115 Hwy. 141 Humphrey (8)**

**Date Test Passed: July 9<sup>th</sup> 2019**

**Flow Achieved: 510 I.G.P.M. 2,313 LITERS/MIN.**

**Two (2) Hour Test Time**



**Signed: Elaine Rose**  
Elaine Rose  
Partner

**This Certificate Expires on: July 1<sup>st</sup>, 2024**